

序号	监测时间	监测指标	监测结果	达标情况	超标倍数	备注
1	2016-10-31, 14	氨氮(mg/L)	0	正常		
2	2016-10-31, 00	化学需氧量(mg/L)	33.58	正常		
3	2016-10-30, 14	氨氮(mg/L)	0.6	正常		
4	2016-10-30, 00	化学需氧量(mg/L)	33.06	正常		
5	2016-10-29, 14	氨氮(mg/L)	1.1	正常		
6	2016-10-29, 00	化学需氧量(mg/L)	31.72	正常		
7	2016-10-28, 14	氨氮(mg/L)	0	正常		
8	2016-10-28, 00	化学需氧量(mg/L)	30.22	正常		
9	2016-10-27, 16	氨氮(mg/L)	0	正常		
10	2016-10-27, 00	化学需氧量(mg/L)	29.07	正常		
11	2016-10-26, 16	氨氮(mg/L)	0	正常		
12	2016-10-26, 00	化学需氧量(mg/L)	28.01	正常		
13	2016-10-25, 16	氨氮(mg/L)	0	正常		
14	2016-10-25, 00	化学需氧量(mg/L)	31.17	正常		
15	2016-10-24, 16	氨氮(mg/L)	0.2	正常		
16	2016-10-24, 00	PH值	8.01	正常		
17	2016-10-24, 00	化学需氧量(mg/L)	33	正常		
18	2016-10-23, 16	氨氮(mg/L)	1	正常		
19	2016-10-23, 00	化学需氧量(mg/L)	34.73	正常		
20	2016-10-22, 16	氨氮(mg/L)	0.1	正常		
21	2016-10-22, 00	化学需氧量(mg/L)	32.09	正常		
22	2016-10-21, 16	氨氮(mg/L)	1.8	正常		
23	2016-10-21, 00	化学需氧量(mg/L)	29.22	正常		

24	2016-10-20, 16	氨氮(mg/L)	0	正常		
25	2016-10-20, 00	化学需氧量(mg/L)	32.82	正常		
26	2016-10-19, 16	化学需氧量(mg/L)	5.1	正常		
27	2016-10-19, 08	氨氮(mg/L)	0	正常		
28	2016-10-19, 00	化学需氧量(mg/L)	31.19	正常		
29	2016-10-18, 08	氨氮(mg/L)	0	正常		
30	2016-10-18, 00	化学需氧量(mg/L)	31	正常		
31	2016-10-17, 08	氨氮(mg/L)	0	正常		
32	2016-10-17, 00	化学需氧量(mg/L)	31.08	正常		
33	2016-10-16, 08	氨氮(mg/L)	1.7	正常		
34	2016-10-16, 00	化学需氧量(mg/L)	31.33	正常		
35	2016-10-15, 08	氨氮(mg/L)	1	正常		
36	2016-10-15, 00	化学需氧量(mg/L)	28.76	正常		
37	2016-10-14, 08	氨氮(mg/L)	0	正常		
38	2016-10-14, 00	化学需氧量(mg/L)	26.44	正常		
39	2016-10-13, 08	氨氮(mg/L)	0	正常		
40	2016-10-13, 00	化学需氧量(mg/L)	25.71	正常		
41	2016-10-12, 08	氨氮(mg/L)	0	正常		
42	2016-10-12, 00	化学需氧量(mg/L)	25.09	正常		
43	2016-10-11, 08	氨氮(mg/L)	0	正常		
44	2016-10-11, 00	化学需氧量(mg/L)	23.19	正常		
45	2016-10-10, 08	氨氮(mg/L)	0	正常		
46	2016-10-10, 00	化学需氧量(mg/L)	24.22	正常		
47	2016-10-09, 08	总镍(mg/L)	<0.02	正常		

48	2016-10-09, 08	氨氮(mg/L)	0	正常		
49	2016-10-09, 08	挥发酚(mg/L)	<0.05	正常		
50	2016-10-09, 08	石油类(mg/L)	0.41	正常		
51	2016-10-09, 08	硫化物(mg/L)	<0.005	正常		
52	2016-10-09, 08	总铬(mg/L)	<0.05	正常		
53	2016-10-09, 08	总镉(mg/L)	<0.005	正常		
54	2016-10-09, 08	总铅(mg/L)	<0.05	正常		
55	2016-10-09, 08	悬浮物(mg/L)	8.7	正常		
56	2016-10-09, 00	化学需氧量(mg/L)	23.9	正常		
57	2016-10-08, 08	氨氮(mg/L)	0	正常		
58	2016-10-08, 00	化学需氧量(mg/L)	24.38	正常		
59	2016-10-07, 08	氨氮(mg/L)	2.1	正常		
60	2016-10-07, 00	化学需氧量(mg/L)	25.81	正常		
61	2016-10-06, 08	氨氮(mg/L)	2.2	正常		
62	2016-10-06, 00	化学需氧量(mg/L)	25.82	正常		
63	2016-10-05, 08	氨氮(mg/L)	2.1	正常		
64	2016-10-05, 00	化学需氧量(mg/L)	27.82	正常		
65	2016-10-04, 08	氨氮(mg/L)	1.5	正常		
66	2016-10-04, 00	化学需氧量(mg/L)	27.83	正常		
67	2016-10-03, 08	氨氮(mg/L)	1.6	正常		
68	2016-10-03, 00	化学需氧量(mg/L)	26.77	正常		
69	2016-10-02, 08	氨氮(mg/L)	2.4	正常		
70	2016-10-02, 00	化学需氧量(mg/L)	25.77	正常		
71	2016-10-01, 08	氨氮(mg/L)	4	正常		

72	2016-10-01, 00	化学需氧量(mg/L)	27.36	正常		
----	----------------	-------------	-------	----	--	--